



Village of Menomonee Falls
 W156 N8480 Pilgrim Road
 Menomonee Falls, WI 53051-3140
 Telephone: (262) 532-4200

STORMWATER MANAGEMENT FACILITIES
 OPERATION AND INSPECTION REPORT

Quarter Section NE 1/4 34 Name of Business/Subdivision BAEUSIS WOOD
 Property Tax ID Number 0132.217 Address of Property _____

Dry Pond	
Wet Pond	X
Other	

Location Of Pond OUTLET 3 (NORTHERN)
#2

Description: 34 N 013

Year Pond Constructed _____ Year of Last Certification _____

Compliance Verification	Design	Actual	Compliant		Comments (Condition of Structure)
			Yes	No	
Primary Outlet Pipe					
Opening Diameter	12	12	X		
Upstream Invert	801.2	800.87	X		
Downstream Invert	799.17	800.68	X		
Length	78.0	73.16	X		
Slope	0.26%	0.26%	X		
Secondary Outlet Pipe					
Opening Diameter	(If Applicable)				
Upstream Invert					
Downstream Invert					
Length					
Slope					
Riser					
Opening Diameter	(If Applicable)				
Elevation	807.9	807.59	X		
Upper Discharge Control					
Opening Diameter	(If Applicable)				
Elevation					

Sketch Outlet

Place Photograph of Pond

Place Photograph of Pond

Inspection Firm: PIONEER ENGINEERING Inspector Name: KALVIN K. KLIMECK
Phone Number: 414 651-0490 Inspection Date: 7/17/14
Address: W3902 CTH B
JOHNSON CREEK, WI 53038

Certifying Professional Name: KALVIN K. KLIMECK
Phone Number: 414 651-0490

Date: 7/17/14

Signature:







